

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer LEM INTERNATIONAL SA
152 Route du Nant-d'Avril
1217 MEYRIN
Switzerland

Measuring instrument A **static DC energy meter**

Type : DCBM 100
Manufacturer's mark or name : LEM
Reference voltage : 150 VDC ... 1.000 VDC
Reference current : 16 A
Destined for the measurement of : electrical energy, in a
- single-phase two-wire network
Accuracy class : B
Environment classes : M1 / E2
Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:
- Description T12552 revision 2;
- Documentation folder T12552-3.

Valid until 26 June 2033

Initially issued 26 June 2023

Remarks This revision replaces the earlier version(s), including its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
22 January 2025

Certification Board