

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer AST (Advanced Sensor Technologies) International GmbH
Bärental 26
75365 Calw
Germany

Measuring instrument **A static DC electrical energy meter**

Type : DC-Meter
Manufacturer's mark or name : AST International GmbH
Reference voltage : 150 VDC ... 1.000 VDC
Reference current : 150 A
Destined for the measurement of : electrical energy, in a
- DC electrical network
Accuracy class : A or B
Environment classes : M1 / E2
Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:

- Description T12596 revision 5;
- Documentation folder T12596-4.

Valid until 16 October 2033

Initially issued 16 October 2023

Remark This revision replaces the earlier versions, including the documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
23 April 2024

Certification Board