

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to
conformity assessment procedures mentioned in article 17 of Directive
2014/32/EU, after having established that the Measuring instrument meets
the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Landis+Gyr
78 km National Road Athens
Corinth GR-20100
Greece

Authorised representative Landis+Gyr Oy
Paperitehtaankatu 9
FI-40100 Jyväskylä
Finland

Measuring instrument **A static Single Phase Electricity Meter**

Type	: E360 AB1D...I2
Manufacturer's mark or name	: Landis+Gyr
Reference voltage	: 230 V
Reference current	: 5 A or 10 A
Destined for the measurement of	: electrical energy, in a - single-phase two-wire network
Accuracy class	: A or B
Environment classes	: M1 / E2
Temperature range	: -10 °C / +70 °C

Further properties are described in the annexes:
– Description T12689 revision 3;
– Documentation folder T12689-2.

Initially issued 1 February 2024

Valid until 1 February 2034

Remark This revision replaces the earlier versions, except for its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
12 July 2024

Certification Board