EU-type examination certificate

Number **T12689** revision 5
Project number 4118115

Issued by

NMi Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer

EYKON AG
Alte Steinhauserstr. 18
6330 Cham
Switzerland

Measuring instrument

A static **Active Electrical Energy Meter**

Type	:	E360 AB1D...I2
Manufacturer's mark or name	:	EYKON
Reference voltage	:	230 V
Reference current	:	5 A or 10 A
Destined for the measurement of	:	electrical energy, in a - single-phase two-wire network
Accuracy class	:	A or B
Environment classes	:	M1 / E2
Temperature range	:	-10 °C / +70 °C

Further properties are described in the annexes:
- Description T12689 revision 5;
- Documentation folder T12689-3;
- Evaluation Report ER12689 revision 5.

Valid until

1 February 2034

Initially issued

1 February 2024

Remark

This revision replaces the earlier versions, including its documentation folder.

Issuing Authority

NMi Certin B.V., Notified Body number 0122
5 November 2026

Certification Board

NMi Certin B.V.
Thijsseweg 11
2629 JA Delft
The Netherlands
T +31 88 636 2332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party liability.

The designation of NMi Certin B.V. as Notified Body can be verified at https://webgate.ec.europa.eu/single-market-compliance-space/home

Reproduction of the complete document only is permitted.

This document is digitally signed and sealed. The digital signature can be verified in the blue ribbon at the top of the electronic version of this certificate.

PRODUCTS
RvA C 681