

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Landis+Gyr
78 km National Road Athens
Corinth GR-20100
Greece

Authorised Representative Landis+Gyr Oy
Paperitehtaankatu 9
FI-40100 Jyväskylä
Finland

Measuring instrument **A static Poly Phase Electricity Meter**

Type : E360 AM3D...I2

Manufacturer's mark or name : Landis+Gyr

Reference voltage : 3x230/400 V

Reference current : 5 A or 10 A

Destined for the measurement of : electrical energy, in a
- three-phase-four-wire network
- two-phase-three-wire network
- single-phase two-wire network

Accuracy class : A or B

Environment classes : M1 / E2

Temperature range : -10 °C / +70 °C

Further properties are described in the annexes:
- Description T12698 revision 4;
- Documentation folder T12698-2.

Valid until 1 February 2034

Initially issued 1 February 2024

Remark This revision replaces the earlier versions, except for its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
12 July 2024

Certification Board