

Issued by NMI Certin B.V.,  
designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Zhejiang Eastron Electronic Co., Ltd.  
No.52, Dongjin Road, Nanhu  
Jiaxing, Zhejiang  
China

Measuring instrument A **static DC energy meter** intended to be integrated in a EV charging system

Type : DCM6-650 and DCM6-200

Manufacturer's mark or name : Eastron

Reference voltage : 150 VDC ... 1000 VDC

Reference current : 130 A (DCM6-650)  
40 A (DCM6-200)

Destined for the measurement of : electrical energy, in a  
- single-phase two-wire network

Accuracy class : A or B

Environment classes : M1 / E2

Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:

- Description T12796 revision 0;
- Documentation folder T12796-1.

Valid until 28 June 2034

Initially issued 28 June 2024

Issuing Authority **NMI Certin B.V., Notified Body number 0122**  
28 June 2024

## Certification Board