

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to
conformity assessment procedures mentioned in article 17 of Directive
2014/32/EU, after having established that the measuring instrument meets
the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Zhejiang Eastron Electronic Co., Ltd.
No.52, Dongjin Road, Nanhu
Jiaxing, Zhejiang
China

Measuring instrument A static **Active Electrical Energy Meter**

Type : SDM630
Manufacturer's mark or name : Eastron
Reference voltage : 3x230/400 V; 3x400 V; 230 V
Reference current : 10 A
Destined for the measurement of : electrical energy, in a
- three-phase four-wire network
- three-phase three-wire network
- single-phase two-wire network

Accuracy class : B or C

Environment classes : M1 / E2

Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:

- Description T12801 revision 5;
- Documentation folder T12801-5.

Valid until 4 November 2034

Initially issued 4 November 2024

Remark This revision replaces the earlier versions, including its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
26 May 2026

Certification Board