

Issued by NMI Certin B.V.,  
designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Zhejiang Eastron Electronic Co., Ltd.  
No.52, Dongjin Road, Nanhu  
Jiaxing, Zhejiang  
China

Measuring instrument A static **Active Electrical Energy Meter**

Type : SDM72  
Manufacturer's mark or name : Eastron  
Reference voltage : 3x230/400 V; 230 V  
Reference current : 10 A  
Destined for the measurement of : electrical energy, in a  
- three-phase four-wire network  
- single-phase two-wire network  
Accuracy class : A or B  
Environment classes : M1 / E2  
Temperature range : -40 °C / +70 °C

Further properties are described in the annexes  
- Description T12831 revision 0  
- Documentation folder T12831-1

Valid until 2 December 2034

Initially issued 2 December 2024

Issuing Authority **NMI Certin B.V., Notified Body number 0122**  
2 December 2024

Certification Board

**NMI Certin B.V.**  
Thijsseweg 11  
2629 JA Delft  
The Netherlands  
T +31 88 636 2332  
[certin@nmi.nl](mailto:certin@nmi.nl)  
[www.nmi.nl](http://www.nmi.nl)

This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party liability.

The designation of NMI Certin B.V. as Notified Body can be verified at <http://ec.europa.eu/growth/tools-databases/nando/>

Reproduction of the complete document only is permitted.

This document is digitally signed and sealed. The digital signature can be verified in the blue ribbon at the top of the electronic version of this certificate.