
	EU-typ) e	examination
			certificate
			Number T12842 revision 3 Project number 3889142 Page 1 of 1
Issued by	to conformity asssessment proced	ures ed tł	lands to perform tasks with respect mentioned in article 17 of Directive nat the measuring instrument meets ve 2014/32/EU, to:
Manufacturer	Carlo Gavazzi Controls SPA Via Safforze 8 32100 Belluno Italy		
Measuring instrument	A static Active Electrical Energy	/ Me	ter
	Туре	:	ЕМ580
	Manufacturer's mark or name	:	Carlo Gavazzi
	Reference voltage	:	3x120/208 3x230/400 V 230 V
	Reference current	:	5 A
	Destined for the measurement of	:	electrical energy, in a - three-phase four-wire network - single-phase two-wire network
	Accuracy class	:	A or B
	Environment classes	:	M2 / E2
	Temperature range	:	-25 °C / +70 °C
	Further properties are described in the annexes: – Description T12842 revision 3; – Documentation folder T12842-2.		
Valid until	4 July 2034		
Initially issued	4 July 2024		
Remark	This revision replaces the earlier version folder.	ersio	n, except for its documentation



NMi Certin B.V.

The Netherlands

T +31 88 636 2332

Thijsseweg 11

2629 JA Delft

<u>certin@nmi.nl</u>

www.nmi.nl

NMi Certin B.V., Notified Body number 0122 7 November 2024

Certification Board

This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party liability.

The designation of NMi Certin B.V. as Notified Body can be verified at http:// ec.europa.eu/growth/tools-databases/nando/

t Reproduction of the complete document only is permitted.

This document is digitally signed and sealed. The digital signature can be verified in the blue ribbon at the top of the electronic version of this certificate.

