

Number **T12892** revision 0
Project number 3859650
Page 1 of 1

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Kaifa Technology Netherlands B.V.
Burgemeester Burgerslaan 40
5245 NH Rosmalen
The Netherlands

Measuring instrument A static **Active Electrical Energy Meter**

Type : MA309M
Manufacturer's mark or name : Kaifa Technology Netherlands B.V.
Reference voltage : 3x230/400 or 3x240/415 V
Reference current : 5, 10 or 20 A (DC)
5 A (CT)
Destined for the measurement of : electrical energy, in a
- three-phase four-wire network
Accuracy class : A or B (DC)
B or C (CT)
Environment classes : M2 / E2 or M1 / E2
Temperature range : -40 °C / +70 °C
Further properties are described in the annexes:
- Description T12892 revision 0;
- Documentation folder T12892-1.

Valid until 30 August 2034

Initially issued 30 August 2024

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
30 August 2024

Certification Board