



EU-type examination certificate

Number **T12905** revision 3
Project number 4115499
Page 1 of 1

Issued by

NMi Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to
conformity assessment procedures mentioned in article 17 of Directive
2014/32/EU, after having established that the measuring instrument meets
the applicable requirements of Directive 2014/32/EU, to:

Manufacturer

Itron Indonesia - PT Mecoindo
EJIP Plot 6B-2 - Cikarang Selatan Bekasi
17550 Jawa Barat
Indonesia

Measuring instrument A static **Active Electrical Energy Meter**

Type : Riva T
Manufacturer's mark or name : Itron Indonesia – PT Mecoindo
Reference voltage : 3x220/380 , 3x230/400 , 3x240/415
Reference current : 5 A
Destined for the measurement of : electrical energy, in a
- three-phase four-wire network
- three-phase three-wire network

Accuracy class : A or B
Environment classes : M1 / E2
Temperature range : -40 °C / +55 °C

Further properties are described in the annexes:

- Description T12905 revision 3;
- Documentation folder T12905-3.

Valid until

14 August 2035

Initially issued

14 August 2025

Remark

This revision replaces the earlier version, except for its documentation
folder.

Issuing Authority

NMi Certin B.V., Notified Body number 0122
8 June 2026

Certification Board

NMi Certin B.V.
Thijssseweg 11
2629 JA Delft
The Netherlands
T +31 88 636 2332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision that
no liability is accepted and that the
manufacturer shall indemnify third-party
liability.

The designation of NMi Certin B.V. as Notified
Body can be verified at [http://](http://ec.europa.eu/growth/tools-databases/nando/)
ec.europa.eu/growth/tools-databases/nando/

Reproduction of the complete
document only is permitted.

This document is digitally signed
and sealed. The digital signature
can be verified in the blue ribbon at
the top of the electronic version of
this certificate.

