

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer **SOCOME C S.A.S**
1-4 Rue de Westhouse
Benfeld, 67230
France

Measuring instrument **A static Active Electrical Energy Meter**

Type	: COUNTIS P34, COUNTIS P36
Manufacturer's mark or name	: SOCOME C S.A.S
Reference voltage	: 3x230/400 V; 3x400 V; 230 V
Reference current	: 10 A
Destined for the measurement of	: electrical energy, in a - three-phase four-wire network - three-phase three-wire network - single-phase two-wire network

Accuracy class : B or C

Environment classes : M1 / E2

Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:

- Description T12944 revision 0;
- Documentation folder T12944-1.

Valid until 19 December 2034

Initially issued 19 December 2024

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
19 December 2024

Certification Board

NMI Certin B.V.
Thijsseweg 11
2629 JA Delft
The Netherlands
T +31 88 636 2332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party liability.

The designation of NMI Certin B.V. as Notified Body can be verified at <http://ec.europa.eu/growth/tools-databases/nando/>

Reproduction of the complete document only is permitted.

This document is digitally signed and sealed. The digital signature can be verified in the blue ribbon at the top of the electronic version of this certificate.