

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Inepro Metering B.V.
Pondweg 7
2153 PK Nieuwe Vennepe
The Netherlands

Measuring instrument A static **Active Electrical Energy Meter**

Type : 6341-xxxx
Manufacturer's mark or name : DZT
Reference voltage : 3x230/400 V
Reference current : 5 A
Destined for the measurement of : electrical energy, in a
- three-phase four-wire network
Accuracy class : A or B
Environmental classes : M1 / E2
Temperature range : -25 °C / +70 °C
Further properties are described in the annexes:
- Description T12953 revision 0;
- Documentation folder T12953-1.

Valid until 4 March 2035

Initially issued 4 March 2025

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
4 March 2025

Certification Board