

Issued by NMI Certin B.V.,  
designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer ZELEC  
1652 Avenue Paul Jullien  
13100 Le Tholonet  
France

Measuring instrument A static **Active Electrical Energy Meter**

Type : EM3100PUM2, EM3100PURSM2,  
EM3100PUMBM2, EM3100RSDTM2,  
EM3100TCIPM2

Manufacturer's mark or name : ZELEC

Reference voltage : 3x230/400 V; 3x400 V; 230 V

Reference current : 10 A

Destined for the measurement of : electrical energy, in a  
- three-phase four-wire network  
- three-phase three-wire network  
- single-phase two-wire network

Accuracy class : B or C

Environment classes : M1 / E2

Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:  
- Description T12990 revision 0;  
- Documentation folder T12990-1.

Valid until 21 April 2036

Initially issued 21 April 2026

Issuing Authority **NMI Certin B.V., Notified Body number 0122**  
21 April 2026

Certification Board