

# EU-type examination certificate

Number **T13002** revision 0  
Project number 3728861  
Page 1 of 1

Issued by

NMi Certin B.V.,  
designated and notified by the Netherlands to perform tasks with respect to  
conformity assessment procedures mentioned in article 17 of Directive  
2014/32/EU, after having established that the measuring instrument meets  
the applicable requirements of Directive 2014/32/EU, to:

Manufacturer

Rishabh Instruments Limited  
F-31 MIDC Satpur  
422007 Nashik  
India

Measuring instrument

A static **Active Electrical Energy Meter**

Type : EX11XX, EX21XX, EX43XX  
Manufacturer's mark or name : Rishabh Instruments Limited  
Reference voltage : 230 V, 3x230V, 3x230/400V  
Reference current : 0,1A (ERXXXX), 1A (ECXXXX), 5A (ECXXXX, EDXXXX)  
Destined for the measurement of : electrical energy, in a  
- three-phase four-wire network (EC43XX, ER43XX, ED43XX)  
- three-phase three-wire network (EC43XX, ER43XX, ED43XX)  
- single-phase two-wire network (EC43XX, ER43XX, ED43XX, EC21XX, ED21XX, ER21XX, EC11XX, ER11XX, ED11XX)  
Accuracy class : B  
Environment classes : M1 / E2  
Temperature range : -25 °C / +55 °C

Further properties are described in the annexes:

- Description T13002 revision 0;
- Documentation folder T13002-1.

Valid until

18 August 2035

Initially issued

18 August 2025

Issuing Authority

**NMi Certin B.V., Notified Body number 0122**  
18 August 2025

Certification Board