



# EU-type examination certificate

Number **T13015** revision 0  
Project number 3931067  
Page 1 of 1

Issued by

NMi Certin B.V.,  
designated and notified by the Netherlands to perform tasks with respect  
to conformity assessment procedures mentioned in article 17 of Directive  
2014/32/EU, after having established that the measuring instrument meets  
the applicable requirements of Directive 2014/32/EU, to:

Manufacturer

Vertiv Group Corporation  
505 N. Cleveland Ave Westerville  
Westerville, Ohio 43082  
United States of America

Measuring instrument **A static Active Electrical Energy Meter**

Type : VEM630  
Manufacturer's mark or name : Vertiv Group Corporation  
Reference voltage : 3x230/400 V; 3x400 V; 230 V  
Reference current : 10 A  
Destined for the measurement of : electrical energy, in a  
- three-phase four-wire network  
- two-phase three-wire network  
- single-phase two-wire network  
Accuracy class : B or C  
Environment classes : M1 / E2  
Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:  
- Description T13015 revision 0;  
- Documentation folder T13015-1.

Valid until

16 June 2035

Initially issued

16 June 2025

Issuing Authority

**NMi Certin B.V., Notified Body number 0122**  
16 June 2025

Certification Board

**NMi Certin B.V.**  
Thijssseweg 11  
2629 JA Delft  
The Netherlands  
T +31 88 636 2332  
[certin@nmi.nl](mailto:certin@nmi.nl)  
[www.nmi.nl](http://www.nmi.nl)

This document is issued under the provision that  
no liability is accepted and that the  
manufacturer shall indemnify third-party  
liability.

The designation of NMi Certin B.V. as Notified  
Body can be verified at [http://](http://ec.europa.eu/growth/tools-databases/nando/)  
[ec.europa.eu/growth/tools-databases/nando/](http://ec.europa.eu/growth/tools-databases/nando/)

Reproduction of the complete  
document only is permitted.

This document is digitally signed  
and sealed. The digital signature  
can be verified in the blue ribbon at  
the top of the electronic version of  
this certificate.

