



# EU-type examination certificate

Number **T13033** revision 0  
Project number 3952848  
Page 1 of 1

Issued by

NMi Certin B.V.,  
designated and notified by the Netherlands to perform tasks with respect to  
conformity modules mentioned in article 17 of Directive 2014/32/EU, after  
having established that the Measuring instrument meets the applicable  
requirements of Directive 2014/32/EU, to:

Manufacturer

SEMAX Solutions a.s.  
Mezi Stromy 505  
252 25 Jinočany  
Czech Republic

Measuring instrument

A static **Active Electrical Energy Meter**

Type : AS3000(V) or AS3500(V)

Manufacturer's mark or name : SEMAX Solutions a.s.

Reference voltage : 3x230/400V or 3x230V (DC/CT)  
3x58/100V or 3x100V (CT)  
3x63/110V or 3x110V (CT)

Reference current : 5 , 10 or 20 A (DC)  
1, 5 or 10 A (CT)

Destined for the measurement of : electrical energy, in a  
- three-phase four-wire network  
- three-phase three-wire network  
- two-phase three-wire network  
- single-phase two-wire network

Accuracy class : A, B or C

Environment classes : M2 / E2

Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:

- Description T13033 revision 0;
- Documentation folder T13033-1.

Valid until

29 September 2035

Initially issued

29 September 2025

Issuing Authority

**NMi Certin B.V., Notified Body number 0122**  
29 September 2025

Certification Board

**NMi Certin B.V.**  
Thijssseweg 11  
2629 JA Delft  
The Netherlands  
T +31 88 636 2332  
certin@nmi.nl  
www.nmi.nl

This document is issued under the provision  
that no liability is accepted and that the  
manufacturer shall indemnify third-party  
liability.

The designation of NMi Certin B.V. as Notified  
Body can be verified at [http://  
ec.europa.eu/growth/tools-databases/nando/](http://ec.europa.eu/growth/tools-databases/nando/)

Reproduction of the complete  
document only is permitted.

This document is digitally signed  
and sealed. The digital signature  
can be verified in the blue ribbon at  
the top of the electronic version of  
this certificate.

