



# EU-type examination certificate

Number **T13076** revision 0  
Project number 3828871  
Page 1 of 1

Issued by

NMi Certin B.V.,  
designated and notified by the Netherlands to perform tasks with respect to  
conformity assessment procedures mentioned in article 17 of Directive  
2014/32/EU, after having established that the measuring instrument meets  
the applicable requirements of Directive 2014/32/EU, to:

Manufacturer

Guochuang Mobile Energy Innovation Center (Jiangsu) Co., Ltd.  
F2, R&D Hub 5, Science and Education Town,  
Changzhou, Jiangsu,  
China

Measuring instrument **A static DC Energy Meter**

Type : EM1030601  
Manufacturer's mark or name : Guochuang Mobile Energy Innovation  
Center (Jiangsu) Co., Ltd.  
Reference voltage : 150...1000 VDC  
Reference current : 130 ADC  
Destined for the measurement of : electrical energy, in a  
- single-phase two-wire network  
Accuracy class : A or B  
Environment classes : M1 / E2  
Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:

- Description T13076 revision 0;
- Documentation folder T13076-1.

Valid until

16 January 2036

Initially issued

16 January 2026

Issuing Authority

**NMi Certin B.V., Notified Body number 0122**  
16 January 2026

Certification Board

**NMi Certin B.V.**  
Thijsseweg 11  
2629 JA Delft  
The Netherlands  
T +31 88 636 2332  
[certin@nmi.nl](mailto:certin@nmi.nl)  
[www.nmi.nl](http://www.nmi.nl)

This document is issued under the provision that  
no liability is accepted and that the  
manufacturer shall indemnify third-party  
liability.

The designation of NMi Certin B.V. as Notified  
Body can be verified at [http://](http://ec.europa.eu/growth/tools-databases/nando/)  
[ec.europa.eu/growth/tools-databases/nando/](http://ec.europa.eu/growth/tools-databases/nando/)

Reproduction of the complete  
document only is permitted.

This document is digitally signed  
and sealed. The digital signature  
can be verified in the blue ribbon at  
the top of the electronic version of  
this certificate.

