

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Itron Indonesia - PT Mecoindo
EJIP Plot 6B-2 - Cikarang Selatan Bekasi
17550 Jawa Barat
Indonesia

Measuring instrument A static **Active Electrical Energy Meter**

Type	: RIVA S
Manufacturer's mark or name	: Itron
Reference voltage	: 220...240 V
Reference current	: 5 A
Destined for the measurement of	: electrical energy, in a - single-phase two-wire network
Accuracy class	: A or B
Environment classes	: M1 / E2
Temperature range	: -40 °C / +55 °C

Further properties are described in the annexes:
- Description T13079 revision 3;
- Documentation folder T13079-1.

Valid until 12 February 2036

Initially issued 12 February 2026

Remark This revision replaces the earlier versions, except for its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
8 June 2026

Certification Board