

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer FRER SRL
Viale Europa, 12
20093 Cologno Monzese (MI)
Italy

Measuring instrument A static **Active Electrical Energy Meter**

Type : C70-100M, C70-100S

Manufacturer's mark or name : FRER SRL

Reference voltage : 3x230/400 V; 3x400 V; 230 V

Reference current : 10 A

Destined for the measurement of : electrical energy, in a
- three-phase four-wire network
- two-phase three-wire network
- single-phase two-wire network

Accuracy class : B or C

Environment classes : M1 / E2

Temperature range : -40 °C / +70 °C

Further properties are described in the annexes;
- Description T13119 revision 0;
- Documentation folder T13119-1.

Valid until 20 October 2035

Initially issued 20 October 2025

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
20 October 2025

Certification Board