

Issued by NMI Certin B.V.,  
designated and notified by the Netherlands to perform tasks with respect to  
conformity assessment procedures mentioned in article 17 of Directive  
2014/32/EU, after having established that the measuring instrument meets  
the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Accuenergy  
440 Comstock Road  
Toronto, Ontario, M1L2H6  
Canada

Measuring instrument **A static DC electrical energy meter** intended to be integrated in a EV  
charging system

Type : AcuDC-301  
Manufacturer's mark or name : Accuenergy  
Reference voltage : 60 VDC ... 1000 VDC  
Reference current : 130 A  
Destined for the measurement of : electrical energy, in a  
- DC electrical network  
Accuracy class : C  
Environment classes : M1 / E2  
Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:  
- Description T13121 revision 0;  
- Documentation folder T13121-1.

Valid until 16 February 2036

Initially issued 16 February 2026

Issuing Authority **NMI Certin B.V., Notified Body number 0122**  
16 February 2026

Certification Board