



EU-type examination certificate

Number **T13149** revision 0

Project number 3728861

Page 1 of 1

Issued by

NMi Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to
conformity assessment procedures mentioned in article 17 of Directive
2014/32/EU, after having established that the measuring instrument meets
the applicable requirements of Directive 2014/32/EU, to:

Manufacturer

TE Connectivity
Freebournes Road, Witham
Essex CM8 3AH
United Kingdom

Measuring instrument

A static **Active Electrical Energy Meter**

Type

: DRR-XX-1P, DRR-XXX-1P, DRR-XXX-3P

Manufacturer's mark or name

: TE Connectivity

Reference voltage

: 230 V, 3x230V, 3x230/400V

Reference current

: 0,1A (DRR-RJX-XX), 1A (DRR-CTX-XX), 5A
(DRR-45-XX, DRR-100-XX)

Destined for the measurement of

: electrical energy, in a
- three-phase four-wire network
(DRR-XXX-3P)
- three-phase three-wire network
(DRR-XXX-3P)
- single-phase two-wire network
(DRR-XX-1P, DRR-XXX-1P, DRR-XXX-3P)

Accuracy class

: B

Environment classes

: M1 / E2

Temperature range

: -25 °C / +55 °C

Further properties are described in the annexes:

- Description T13149 revision 0;
- Documentation folder T13149-1.

Valid until

30 December 2035

Initially issued

30 December 2025

Issuing Authority

NMi Certin B.V., Notified Body number 0122

30 December 2025

Certification Board

NMi Certin B.V.
Trijsseweg 11
2629 JA Delft
The Netherlands
T +31 88 636 2332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision that
no liability is accepted and that the
manufacturer shall indemnify third-party
liability.

The designation of NMi Certin B.V. as Notified
Body can be verified at <http://ec.europa.eu/growth/tools-databases/nando/>

Reproduction of the complete
document only is permitted.

This document is digitally signed
and sealed. The digital signature
can be verified in the blue ribbon at
the top of the electronic version of
this certificate.

