

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer SENECA s.r.l.
Via Austria 26
Padova
Italy

Measuring instrument A static **Active Electrical Energy Meter**

Type : S534-100-MOD-MID

Manufacturer's mark or name : SENECA s.r.l.

Reference voltage : 3x230/400 V; 3x400 V; 230 V

Reference current : 10 A

Destined for the measurement of : electrical energy, in a
- three-phase four-wire network
- three-phase three-wire network
- single-phase two-wire network

Accuracy class : B or C

Environment classes : M1 / E2

Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:

- Description T13157 revision 0;
- Documentation folder T13157-1.

Valid until 12 March 2036

Initially issued 12 March 2026

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
12 March 2026

Certification Board