

Issued by NMI Certin B.V.,
 designated and notified by the Netherlands to perform tasks with respect to
 conformity assessment procedures mentioned in article 17 of Directive
 2014/32/EU, after having established that the measuring instrument meets the
 applicable requirements of Directive 2014/32/EU, to:

Manufacturer Carlo Gavazzi Controls SPA
 Via Safforze 8
 32100 Belluno
 Italy

Measuring instrument A static **Active Electrical Energy Meter**

Type : EM630 as Transformer Connected Meter (TCM)
 EM640 as Direct Connected Meter (DCM)

Manufacturer's mark or name : Carlo Gavazzi

Reference voltage : 3x120/208 V ... 3x230/400 V (EM640)
 3x208 V and 3x400 V (EM640)
 230 V (EM640)

3x230/400 V (EM630)
 3x400V (EM630)

Reference current : 5 A

Destined for the measurement of : electrical energy, in a
 - three-phase four-wire network
 - three-phase three-wire network
 - single-phase two-wire network

Accuracy class : A or B

Environment classes : M2 / E2

Temperature range : -25 °C / +70 °C

Further properties are described in the annexes
 - Description T13161 revision 0
 - Documentation folder T13161-1

Valid until 23 April 2036

Initially issued 23 April 2026

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
 23 April 2026

Certification Board