



EU-type examination certificate

Number **T13184** revision 0
Project number 4059876
Page 1 of 1

Issued by

NMi Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to
conformity assessment procedures mentioned in article 17 of Directive
2014/32/EU, after having established that the measuring instrument meets
the applicable requirements of Directive 2014/32/EU, to:

Manufacturer

Conrad Electronic SE
Klaus-Conrad-Str. 1
D-92242 Hirschau
Germany

Measuring instrument A static **Active Electrical Energy Meter**

Type : TC-DRT-341A MID, TC-DRT-341D
[Battery / Reset / Modbus / M-Bus] MID, TC-
DRT-341D CT [Battery / Reset / Modbus /
M-Bus] MID, TC-DRT-341C [Modbus / M-
Bus] MID, TC-DRT-341C CT [Modbus / M-
Bus] MID

Manufacturer's mark or name : Conrad Electronic S.E.

Reference voltage : 3x230/400 V

Reference current : 5 or 10 A (TC-DRT-341A MID, TC-DRT-
341D MID)
10 A (TC-DRT-341C MID)
1,5 A (TC-DRT-341C CT MID, CT-DRT-
341D CT MID)

Destined for the measurement of : electrical energy, in a
- three-phase four-wire network

Accuracy class : A or B

Environment classes : M1 / E2

Temperature range : -25 °C / +55 °C

Further properties are described in the annexes

- Description T13184 revision 0
- Evaluation Report ER13184 revision 0
- Documentation folder T13184-1

Valid until 17 July 2036

Initially issued 17 July 2026

Issuing Authority

NMi Certin B.V., Notified Body number 0122
17 July 2026

Certification Board

NMi Certin B.V.
Thijssseweg 11
2629 JA Delft
The Netherlands
T +31 88 636 2332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision that
no liability is accepted and that the manufacturer
shall indemnify third-party liability.

The designation of NMi Certin B.V. as Notified
Body can be verified at
[https://webgate.ec.europa.eu/single-market-
compliance-space/home](https://webgate.ec.europa.eu/single-market-compliance-space/home)

Reproduction of the complete
document only is permitted.

This document is digitally signed
and sealed. The digital signature
can be verified in the blue ribbon
at the top of the electronic
version of this certificate.

