



EU-type examination certificate

Number **T13205** revision 1
Project number 4139392
Page 1 of 1

Issued by

NMi Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to
conformity assessment procedures mentioned in article 17 of Directive
2014/32/EU, after having established that the measuring instrument meets
the applicable requirements of Directive 2014/32/EU, to:

Manufacturer

Caravan Park Electrical Services Ltd.
Vale Road Industrial Estate
Spilsby, Lincolnshire PE23 5HE
United Kingdom

Measuring instrument **A static Active Electrical Energy Meter**

Type : 033009, 033010
Manufacturer's mark or name : Caravan Park Electrical Services Ltd.
Reference voltage : 230 V
Reference current : 5 A
Destined for the measurement of : electrical energy, in a
- single-phase two-wire network
Accuracy class : B
Environment classes : M1 / E2
Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:

- Description T13205 revision 1;
- Documentation folder T13205-2;
- Evaluation Report ER13205 revision 1.

Valid until

18 March 2036

Initially issued

18 March 2026

Remarks

This revision replaces the earlier version, including its documentation folder.

Issuing Authority

NMi Certin B.V., Notified Body number 0122
1 October 2026

Certification Board

NMi Certin B.V.
Thijssseweg 11
2629 JA Delft
The Netherlands
T +31 88 636 2332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision that
no liability is accepted and that the
manufacturer shall indemnify third-party
liability.

The designation of NMi Certin B.V. as Notified
Body can be verified at
<https://webgate.ec.europa.eu/single-market-compliance-space/home>

Reproduction of the complete
document only is permitted.

This document is digitally signed
and sealed. The digital signature
can be verified in the blue ribbon at
the top of the electronic version of
this certificate.

