

Issued by

NMi Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer

Landis+Gyr Olympus AG
Alte Steinhäuserstrasse 18
CH-6330 Cham
Switzerland

Authorised representative

Landis+Gyr Oy
Paperitehtaankatu 9
FI-40100 Jyväskylä
Finland

Measuring instrument **A static poly phase Active Electrical Energy Meter**

Type : E360-AM3D...S3

Manufacturer's mark or name : Landis+Gyr

Reference voltage : - 3x230/400 V
- 230 V

Reference current : 5 A or 10 A

Destined for the measurement of : electrical energy, in a
- three-phase four-wire network
- single-phase two-wire network

Accuracy class : A or B

Environment classes : M1 / E2

Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:

- Description T13267 revision 0;
- Documentation folder T13267-1.

Valid until

15 June 2036

Initially issued

15 June 2026

Issuing Authority

NMi Certin B.V., Notified Body number 0122
15 June 2026

Certification Board