

EU-type examination certificate

Number **T13287** revision 0
Project number 4136299
Page 1 of 1

Issued by

NMi Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to
conformity assessment procedures mentioned in article 17 of Directive
2014/32/EU, after having established that the measuring instrument meets
the applicable requirements of Directive 2014/32/EU, to:

Manufacturer

Bender GmbH und Co. KG
Londorfer Straße 65
Grünberg
Germany

Measuring instrument

A static **Active Electrical Energy Meter**

Type : EM443-D-35-MID

Manufacturer's mark or name : Bender GmbH und Co. KG

Reference voltage : 3x230/400 V; 3x400 V; 230 V

Reference current : 10 A

Destined for the measurement of : electrical energy, in a
- three-phase four-wire network
- three-phase three-wire network
- single-phase two-wire network

Accuracy class : B or C

Environment classes : M1 / E2

Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:

- Description T13287 revision 0;
- Documentation folder T13287-1.
- Evaluation Report ER13287 revision 0.

Valid until

14 September 2036

Initially issued

14 September 2026

Issuing Authority

NMi Certin B.V., Notified Body number 0122
14 September 2026

Certification Board