



EU-type examination certificate

Number **T12788** revision 0
Project number 3783066
Page 1 of 1

Issued by

NMi Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to
conformity assessment procedures mentioned in Article 13 of Directive
2014/31/EU, after having established that the measuring instrument meets
the applicable requirements of Directive 2014/31/EU, to:

Manufacturer

HISPANO EUROPEA DE PESAJE S.A.
Carretera Zamora, 1A, N-360, 154, Nave 5
24231 Onzonilla
Spain

Measuring instrument

A Non-automatic weighing instrument
Type : HSP

Further properties are described in the annex:
– Description T12788 revision 0.

Valid until

18 March 2034

Initially issued

18 March 2024

Issuing Authority

NMi Certin B.V., Notified Body number 0122
18 March 2024

Certification Board

NMi Certin B.V.
Thijsseweg 11
2629 JA Delft
The Netherlands
T +31 88 636 2332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision that
no liability is accepted and that the
manufacturer shall indemnify third-party
liability.

The designation of NMi Certin B.V. as Notified
Body can be verified at [http://
ec.europa.eu/growth/tools-databases/nando/](http://ec.europa.eu/growth/tools-databases/nando/)

Reproduction of the complete
document only is permitted.

This document is digitally signed
and sealed. The digital signature
can be verified in the blue ribbon at
the top of the electronic version of
this certificate.





Description

Number **T12788** revision 0

Project number 3783066

Page 1 of 3

1 General information about the non-automatic weighing instrument

All properties of the non-automatic weighing instrument, whether mentioned or not, shall not be in conflict with the legislation.

This certificate contains references to other certificates. The properties mentioned in these certificates shall be observed in addition to the properties mentioned in this certificate.

1.1 Essential parts

Indicator:

Producer	Type	Certificate number
Técnicas de Electrónica y Automatismos, S.A.	MATRIX II	E-09.02.C09
Técnicas de Electrónica y Automatismos, S.A.	SMART	E-03.02.C04
Técnicas de Electrónica y Automatismos, S.A.	SWIFT Series	TC11633
Técnicas de Electrónica y Automatismos, S.A.	SMART DIGITAL series	TC12571

Any analog passive load cell(s) may be used under this certificate for instruments as described in WELMEC 2.4 Issue 2021, provided the following conditions are met:

- There is a respective certificate (EN45501) or an OIML Certificate (R 60) issued for the load cell by a Notified Body responsible for type examination under Directive 2014/31/EU or Directive 2014/32/EU;
- The load cell shall comply with humidity class **CH** or **SH**;
- The certificate contains the load cell types and the necessary load cell data required for the manufacturer's declaration of compatibility of modules (EN 45501:2015 clause F.4), and any particular installation requirements;
- The compatibility of load cells and indicator is established by the manufacturer by means of the compatibility of modules form, contained in EN 45501:2015 clause F.4, at the time of putting into use;
- The load transmission must conform to one of the examples shown in WELMEC 2.4 Issue 2021.

Digital load cell:

Producer	Type	Certificate number
Técnicas de Electrónica y Automatismos, S.A.	740D	E-04.02.C06

Any other digital load cell(s) may be used under this certificate for instruments as described in WELMEC 2.4 Issue 2021, provided the following conditions are met:

- There is a respective certificate (EN45501:2015) or an OIML Certificate (R 60 (2000), R 60:2017 or R 60:2021) issued for the load cell by a Notified Body responsible for type examination under Directive 2014/31/EU or Directive 2014/32/EU;
- The load cell shall comply with humidity class **CH** or **SH**;
- The digital load cell complies with the appropriate electromagnetic environment class;

- The certificate contains the load cell types and the necessary load cell data required for the manufacturer's declaration of compatibility of modules (EN 45501:2015 clause F.5), and any particular installation requirements;
- The compatibility of load cells and indicator is established by the manufacturer by means of the compatibility of modules form, contained in EN 45501:2015 clause F.5, at the time of putting into use;
- The load transmission must conform to one of the examples shown in WELMEC 2.4 Issue 2021.

1.2 Essential characteristics

Accuracy class	III or IIII
Maximum number of scale intervals	$n \leq$ number of scale intervals in the certificates involved

1.3 Essential shapes

The data plate is secured against removal by sealing or will be destroyed when removed.

1.4 Conditional parts

The instrument may be equipped with the following parts that further process the measurement result without modification under the conditions stated in the table:

Part	Condition(s)	Reference document
Simple recipient printer	CE marking present	WELMEC 2.10 clause 3.1.3
Printer Data Storage Device	CE marking present and the part is certified to be connected to a weighing instrument by a Notified Body responsible for type examination under Directive 2014/31/EU.	WELMEC 2.10 clause 3.1.3

The non-automatic weighing instrument is fitted with a levelling device and a level indicator, unless the instrument is installed in a fixed position. A ring on the level indicator indicates when the maximum tilt is exceeded.

1.5 Non-essential parts

The non-automatic weighing instrument may be connected to non-essential devices, for example but not limited to bar code readers, foot switches, second displays and cash drawers, provided that:

- They do not present primary data used for purposes mentioned in Directive 2014/31/EU Article 1(2), (a) to (f) unless the (Preliminary observation) in Directive 2014/31/EU Annex I is satisfied;
- They do not lead to an instrument having other essential characteristics than those fixed by this certificate.



Description

Number **T12788** revision 0
Project number 3783066
Page 3 of 3

2 Seals

To secure components that may not be dismantled or adjusted by the user, the non-automatic weighing instrument has to be secured in a suitable manner on the locations indicated in the certificates involved.

The connecting cable of the load cell or the junction box is provided with possibility to seal.

3 Conditions for conformity assessment

The marks, facilities for the marks and the inscriptions on the non-automatic weighing instrument fulfil the requirements of Directive 2014/31/EU Annex III clause 1.

The compatibility of load cells and indicator is established by the manufacturer by means of the compatibility of modules form, contained in EN 45501:2015 clause F.4 or clause F.5, at the time of putting into use.